

Sprinkler Save

Date: July 31, 2011

Time: 17:30 hours

Address: 7100 Block of W. 126th
Savage, MN

Savage Fire Department responded for a Water Flow Alarm. Alarm was triggered by a fire in a Cabinet Shop. Sprinkler system kept the fire to a minimum, and there was some water and smoke damage to rest of the unit.

Shakopee Fire was called to assist.

The preliminary cause of the fire was a box fan that had been recalled.