

Fire Sprinkler Save

Coon Rapids FD responded to fire alarm at a townhouse. Crews arrived to find that the sprinkler system had put the fire out. Crews began ventilation and shutting off the sprinkler system.

The fire originated in a laundry basket that was sitting on the dryer. The fire was contained to the sheets in the laundry basket.

Cause was determined to be massage oils in the sheets that spontaneously combusted.



Fire Sprinkler Save

