

Sprinkler Save in a Commercial Building

On 2/22/12 at 1820, the Lake Johanna Fire Department was dispatched to a water flow alarm at a commercial building. The crews arrived and found nothing showing from the outside. Upon gaining access to the building, they encountered a smell of smoke with a slight haze in the building. After further investigation, they discovered a sprinkler head flowing that had extinguished a fire in a paint booth that originated from a 55 gallon plastic trash can that was below the head.

