

## **Sprinkler Save**

**Date:** July 31, 2011

**Time:** 17:30 hours

**Address:** 7100 Block of W. 126<sup>th</sup>  
Savage, MN

Savage Fire Department responded for a Water Flow Alarm. Alarm was triggered by a fire in a Cabinet Shop. Sprinkler system kept the fire to a minimum, and there was some water and smoke damage to rest of the unit.

Shakopee Fire was called to assist.

The preliminary cause of the fire was a box fan that had been recalled.